



Total Quality. Assured.

545 E Algonquin Road, Suite H  
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667  
[intertek.com](http://intertek.com)

Published: August 7, 2019  
Revised:

Public Notice ID: 19-12  
Page 1 of 2

## Safety Concern with Intertek Certified Product / Souci de sécurité avec le produit certifié Intertek

### Goodman Company, L.P. of Houston, Texas

Notification Type:	Safety / Sécurité
Certification Type:	ETL Listed - US and Canada

#### **Notification**

Intertek notifies consumers, retailers and distributors of a potential safety concern involving the Intertek Certified products identified below. / Intertek informe les consommateurs, les détaillants et les distributeurs d'une préoccupation potentielle en matière de sécurité impliquant les produits certifiés Intertek identifiés ci-dessous.

#### **Company Identification**

Goodman Company, L.P. of Houston, Texas

#### **Product Identification**

Models that begin with the following prefixes are included in this recall: EKTC15, EKTH15, PMC15, PMH12, PMH15, PTC15, PTH12, PTH15, UCYB15 and UCYH15. Only units with the first four digits of the serial numbers in the range between 1001 and 1709 are affected. The model number and serial number are located on a label behind the front cover of the unit. See CPSC recall 18-113.

#### **Hazard Involved**

Goodman has received nine reports of PTACs catching on fire, including one report of smoke inhalation with medical attention

#### **What To Do**

Usage should be immediately discontinued and returned to the point of purchase. Distributors and retailers should discontinue sales and return inventories to their suppliers. / L'utilisation doit être immédiatement abandonnée et retournée au point d'achat. Les distributeurs et les détaillants devraient cesser les ventes et les stocks de retour à leurs fournisseurs.



Total Quality. Assured.

Published: August 7, 2019  
Revised:

**Photos and Images**

Link to CPSC Recall:  
<https://www.cpsc.gov/Recalls/2018/Goodman-Company-Recalls-Packaged-Terminal-Air-Conditioners-and-Heat-Pumps-Due-to-Burn-and-Fire-Hazards>

545 E Algonquin Road, Suite H  
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667  
**intertek.com**

Public Notice ID: 19-12  
Page 2 of 2

